ST. TAMMANY PARISH COUNCIL

RESOLUTION

RESOLUTION COUNCIL SERIES NO: C-4308

THERESA L. FORD, COUNCIL CLERK

COUNCIL SPONSOR: TANNER/BRISTER PROVIDED BY: LEGAL/ENVIRONMENTAL SERVICES

RESOLUTION ACKNOWLEDGING THE RECEIPT AND REVIEW OF THE 2014 MUNICIPAL WATER POLLUTION PREVENTION ENVIRONMENTAL AUDIT REPORT FOR THE WESTWOOD SEWAGE TREATMENT FACILITY (WARD 4, DISTRICT 5)

WHEREAS, St. Tammany Parish Government owns and operates the Westwood Sewage Treatment Facility; and

WHEREAS, the Louisiana Pollutant Discharge Elimination System (LPDES) permit which authorized effluent discharge from the Westwood Sewage Treatment Facility mandates the Parish to institute a program directed towards pollution prevention in order to improve operating efficiency and extend the useful life of the treatment facility; and

WHEREAS, pursuant to Part II, Section C of LPDES permit LA0063991, the Parish Government must complete an annual Environmental Audit Report for the life of the permit, and a copy of such Environmental Audit Report is attached hereto.

THE PARISH OF ST. TAMMANY HEREBY RESOLVES that the St. Tammany Parish Council acknowledges the receipt of the 2014 Municipal Water Pollution Prevention Environmental Audit Report for the Westwood Sewage Treatment Facility and its finding that no actions are necessary at this time for compliance achievement.

THIS RESOLUTION HAVING BEEN SUBMITTED TO A VOTE, THE VOTE THEREON WAS AS FOLLOWS:

MOVED FOR ADOPTION BY:	SECONDED BY:
YEAS:	
NAYS:	
ABSTAIN:	
ABSENT:	
	ED ADOPTED ON THE 2 DAY OF <u>APRIL</u> , 2015, AT SH COUNCIL, A QUORUM OF THE MEMBERS BEING
	RICHARD E. TANNER, COUNCIL CHAIRMAN
ATTEST:	

Resolution Administrative Comment

RESOLUTION TO ACKNOWLEDGE THE RECEIPT AND REVIEW OF THE 2014 MUNICIPAL WATER POLLUTION PREVENTION ENVIRONMENTAL AUDIT REPORT FOR THE WESTWOOD SEWAGE TREATMENT FACILITY (WARD 4, DISTRICT 5).

Pursuant to the permit authorizing effluent discharge, this Resolution is required to acknowledge the Environmental Audit and identify any compliance actions to be taken. No compliance actions were indicated.

LOUISIANA

MUNICIPAL WATER POLLUTION PREVENTION

MWPP



	Westwood Cowage Treatment
Facility Name:	Westwood Sewage Treatment Facility
LPDES Permit Number:	LA0063991
Agency Interest (AI) Number:	19917
Address:	P. O. Box 628 Covington, LA 70434
	Westwood Regional Sewer Treatment Location: Judge Tanner Blvd, Mandeville, LA
Parish:	St. Tammany
(Person Completing Form) Name:	Greg Gorden
Title:	Department of Environmental Services Director
Date Completed:	Dec 2013 - Nov 2014

INSTRUCTIONS

- 1. Complete only the sections of the Environmental Audit which apply to your wastewater treatment system. Leave sections that do not apply blank and enter a "0" for the point value.
- 2. Parts 1 through 7 contain questions for which points may be generated. These points are intended to communicate to the department and the governing body or owner what actions will be necessary to prevent effluent violations. Place the point totals from parts 1 through 7 on the Point Calculation page.
- 3. Add up the point totals.
- 4. Submit the Environmental Audit to the governing body or owner for review and approval.
- 5. The governing body must pass a resolution which contains the following items:
 - a. The resolution or letter must acknowledge the governing body or owner has reviewed the Environmental Audit.
 - b. This resolution must indicate <u>specific</u> actions, if any, will be taken to maintain compliance and prevent effluent violations. Proposed actions should address the parts where maximum or close to maximum points were generated in the Environmental Audit.
 - c. The resolution should provide any other information the governing body deems appropriate.

PART 1: INFLUENT FLOW/LOADINGS (all plants)

A. List the average monthly volumetric flows and CBOD loadings received at your facility during the last reporting year.

Column 1 Average Monthly Flow (million gallons per day, MGD)		Column 2 Average Monthly CBOD5 Concentration (mg/l)		Column 3 Average Monthly CBOD5 Loading (pounds per day, lb/day)
0.191	X	219	x 8.34 =	348.9
0.206	X	219	x 8.34 =	376.3
0.266	X	219	x 8.34 =	485.8
0.204	X	219	x 8.34 =	372.6
0.201	X	219	x 8.34 =	367.1
0.223	X	219	x 8.34 =	407.3
0.228	X	219	x 8.34 =	416.4
0.21	X	219	x 8.34 =	383.6
0.203	X	219	x 8.34 =	370.8
0.195	X	219	x 8.34 =	356.2
0.187	X	219	x 8.34 =	314.5
0.186	X	219	x 8.34 =	339.7

^{*} Please note influent value is one time sample taken for LPDES permit renewal data 2009.

CBOD loading = Average Monthly Flow (in MGD) x Average Monthly CBOD concentration (in mg/l) x 8.34

B. List the design flow and design CBOD loading for your facility in the blanks below. If you are not aware of these design quantities, refer to your Operation and Maintenance (O&M) Manual or contact your consulting engineer.

Design Flow, MGD:	0.550 MGD	x 0.90 =	0.495
Design CBOD, lb/day:	1000	x 0.90 =	900

							Per	mit #:	LA(0063	991		
C.	How many m (WWTF) exc point total. V	ceed 90	% of c	lesign	flow?	Circle	the nu	ımber o	f mon				
	months 0	1	2	3	4	5	6	7	8	9	10	11	12
	points 0	0	0	0	0	5	5	7 5	5	5	5	5	5
					Write	e 0 or 5	in the	C poir	ıt total	box	0	C Poir	nt Total
D.	How many m Circle the nu below at the	mber o											
	months 0	1	2	3	4	5	6	7 15	8	9	10	11	12
	points 0	5	5	10	10	15	15	15	15	15	15	15	15
				Write	0, 5, 10	0 or 15	in the	D poin	ıt total	box	0	D Poir	nt Total
Е.	How many m of the design the point total	loadin	g? Ciı	cle the	numb	er of n							
	months 0	1	2	3	4	5	6	7	8	9	10	11	12
	points 0	0	5	5	5	10	10	7 10	10	10	10	10	10
				W	rite 0,	5,or 10) in the	E poir	ıt total	box	0	E Poir	nt Total
F.	How many m design loading point total in	ng? Cin	cle the	e numb	er of r	nonths							
	months 0	1	2	3	4	5	6	7	8	9	10	11	12
	points 0	10	20	30	40	50	50	50	50	50	50	50	50
		W	rite 0,	10, 20	, 30, 4	0 or 50) in the	e F poir	ıt total	box	0	F Poin	ıt Total

Also enter this value or 80, whichever is less, on the point calculation table on page 16.

TOTAL POINT VALUE FOR PART 1: $0 \pmod{80}$

Add together each point total for C through F and place this sum in the box below at the right.

G.

PART 2: EFFLUENT QUALITY / PLANT PERFORMANCE

A. List the monthly average effluent CBOD and TSS concentrations produced by your facility during the last reporting year.

Month	Column 1 Average Monthly CBOD (mg/l)	Column 2 Average Monthly TSS (mg/l)
December 2013	4	3
January 2014	2	3
February 2014	4	1
March 2014	6	3
April 2014	5	2
May 2014	8	4
June 2014	4	8
July 2014	6	4
August 2014	5	4
September 2014	4	4
October 2014	4	5
November 2014	4	7

B. List the monthly average permit limits for your facility in the blanks below.

_	Permit Limit		90% of Permit Limit
CBOD, mg/l	10	x 0.90 =	9
TSS, mg/l	15	x 0.90 =	13.5

							Per	mit #:	LA()063	991		
C.	Continuous I	Dischar	rge to S	Surface	e Wate	r.		Į.					
i .	How many m Circle the num the box below	mber o	of mon	ths and							_		
	months 0 points 0	1 0	2 10	3 20	4 30	5 40	6 40	7 40	8 40	9 40	10 40	11 40	12 40
			Wri	te 0, 1	0, 20, 3	30 or 4	0 in th	e i poir	nt total	box	0	i Poin	t Total
ii.	How many m number of me at the right.								_				
	months 0	1	2	3	4	5	6	7	8	9	10	11	12
	points 0	5	5	10	10	10	10	10	10	10	10	10	10
iii.	How many m	mber o	of mon	efflue ths and	ent TSS	S (Colu	ımn 2)		1 90%	of the	permit	limits	
	the box below	v at the	e right.										
	months 0	1	2	3	4	5	6	7	8	9	10	11	12
	points 0	0	10	20	30	40	40	40	40	40	40	40	40
			Write	e 0, 10,	, 20, 30	or 40	in the	iii poii	nt total	box	0	iii Poi	nt Total
iv.	How many m number of me at the right.					•			•				
	months 0	1	2	3	4	5	6	7	8	9	10	11	12
	points 0	5	5	10	10	10	10	10	10	10	10	10	10
				Wr	ite 0, 5	, or 10	in the	iv poir	nt total	box	0	iv Poi	nt Total
v.	Add together	each p	oint to	otal for	i throu	ıgh iv	and pla	ace this	s sum i	n the b	ox bel	ow at t	he right
				TOT	AL PO	INT '	VALU	E FOF	R PAR	T 2:	0	(max	= 100)

	Permit #: LA0063991
D.	Other Monitoring and Limitations
i.	At any time in the past year was there and exceedance of a permit limit for other pollutants such as: ammonia-nitrogen, phosphorus, pH, total residual chlorine, or fecal coliform?
	\vee Check one box. \square Yes \square No If Yes, Please describe:
ii.	At any time in the past year was there a "failure" of a Biomonitoring (Whole Effluent Toxicity) test of the effluent?
	$\sqrt{\text{Check one box.}}$ Yes $\boxed{\chi}$ No If Yes, Please describe:
	N/A - biomonitoring not required for this facility.
iii.	At any time in the past year was there an exceedance of a permit limit for a toxic substance?
	$\sqrt{\text{Check one box.}}$ Yes \boxed{X} No If Yes, Please describe:

PART 3: AGE OF THE WASTEWATER TREATMENT FACILITY

	Current Year	_	Answer to A	=	Age in years
	2014		1997 & 200	<u>)</u> 4	17 & 10
Enter Age	e in Part C below.				
√ Check 1	the type of treatmer	nt fa	acility that is employ	ed.	
					FACTOR
X	Mechanical Tre (trickling filter, sludge, etc) Specify Type:			udge	2.5
	Aerated Lagoon	n			2.0
	Stabilization Po	ond			1.5
	Other Specify Type:				1.0
			the type of facility total point value for		ommunity employs by the
TOTAL	POINT VALUE F	OF	R PART 3 =		

Also enter this value or 50, whichever is less, on the point calculation table on page 16.

D. Please attach a schematic of the treatment plant.

SEE ATTACHED DIAGRAM.

	Permit #:	LA0063991
--	-----------	-----------

PART 4: OVERFLOWS AND BYPASSES

A. i.	List the number of times in the last year there was an overflow, bypass or unpermitted
	discharge of untreated or incompletely treated wastewater due to heavy rain:
ii.	List the number of bypasses, overflows or unpermitted discharges shown in A (i) that were within the collection system and the number at the treatment plant
	Collection System: 0 Treatment Plant: 0
B. i.	List the number of times in the last year there was an overflow, bypass or unpermitted discharge of untreated or incompletely treated wastewater due to equipment failure, either at the treatment plant or due to pumping problems in the collection system:
	✓ Check one box. \square 0 = 0 points \square 3 = 15 points \square 4 = 30 points \square 2 = 10 points \square 5 or more = 50 points
ii.	List the number of bypasses, overflows or unpermitted discharges shown in B (i) that were within the collection system and the number at the treatment plant
	Collection System: 0 Treatment Plant: 0
C.	Specify whether the bypasses came from the city/village/town sewer system or from contract or tributary communities/sanitary districts, etc
D.	Add the point values checked for A and B and place the total in the box below.
	TOTAL POINT VALUE FOR PART 4: 0 (max = 100) Also enter this value or 100, whichever is less, on the point calculation table on page 16.
Е.	List the person responsible (name and title) for reporting overflows, bypasses or unpermitted discharges to State and Federal authorities:
	Tim Brown, Utility Manager or Greg Gorden, Director - Dept of Enviro Services
	Describe the procedure for gathering, compiling and reporting:
	Field staff reports incidents, management notifies DEQ verbally and/or written

PART 5: SLUDGE STORAGE AND DISPOSAL SITES

A. Sludge Storage

How many months of sludge storage capacity does your facility have available, either on-site or off-site?

Circle the number of months and the corresponding point total. Write the point total in the box below at the right.

 months
 <2</th>
 2

 points
 50
 30

 3
 4-5
 >6

 20
 10
 0

Write 0, 10, 20, 30 or 40 in the A point total box 20 A Point Total

B. For how many months does your facility have access to (and approval for) sufficient land disposal sites to provide proper land disposal?

Circle the number of months and the corresponding point total. Write the point total in the box below at the right.

 months
 <2</th>
 6-11
 12-23
 24-35
 >36

 points
 50
 30
 20
 10
 0

Write 0, 10, 20, 30 or 40 in the B point total box 20 B Point Total

C. Add together the A and B point values and place the sum in the box below at the right:

TOTAL POINT VALUE FOR PART 5: 40 (max = 100)

Also enter this value or 100, whichever is less, on the point calculation table on page 16.

Permit #:	LA0063991
-----------	-----------

PART 6: NEW DEVELOPMENT

Α.	Please provide the follow were installed during the	C	r the tota	al of all sewer line extensions which
	Design Population:	N/A		
	Design Flow:	N/A	MGD	
	Design BOD:	N/A	mg/l	
В.		either flow or poll		he community or expanded production adings to the sewerage system were
	√ Check one box.	Yes = 15 p	oints	X No = 0 points
	If Yes, Please describe:			
		1NO		
	List any new pollutants:	IN/A		
С.				residential) anticipated in the next to the sewerage system could
	√ Check one box.	Yes = 15 p	oints	X No = 0 points
	If Yes, Please describe:			
	-y ,	NOT SIGNITI	cant	
	List any new pollutants ye	ou anticipate:		
	Holy I rimity Church & Scho	ooi wiii be constructe	a ana cor	nnected to this system. will not
	significantly increase the flo	w/pollutant loadings	, should b	e less than 20,000gpd total.
Э.	Add together the point va	lue checked in B a	nd C and	I place the sum in the box below.
		TOTAL POINT	YALU:	E FOR PART 6: 0 (max = 30)

Also enter this value or 30, whichever is less, on the point calculation table on page 16.

L110003771	Permit #:	LA0063991
------------	-----------	-----------

PART 7: OPERATOR CERTIFICATION AND EDUCATION

۸.	What was the name of the operator-in-charge for the reporting year?
	Name: Gilbert McKenzie
3.	What is his or her certification number: **Cert.#: 5833**
C.	What level of certification is the operator-in-charge required to have to operate the wastewater treatment facility? Level Required: II
).	What is the level of certification of the operator-in-charge?
	Level Certified: IV
Ξ.	Was the operator-in-charge of the report year certified at least at the grade level required in order to operate this plant?
	$\sqrt{\text{Check one box.}}$ Yes = 0 points
	Write 0 or 50 in the E point total box 0 E Point Total
r.	Has the operator-in-charge maintained recertification requirements during the reporting year?
	√ Check one box. X Yes No
j.	How many hours of continuing education has the operator-in-charge completed over the last two calendar years?
	$\sqrt{\text{Check one box.}}$ $\sqrt{\text{Check one box.}}$ > 12 hours = 0 points $\sqrt{\text{check one box.}}$ < 12 hours = 50 points
	Write 0 or 50 in the G point total box 0 Point Total
I.	Is there a written policy regarding continuing education an training for wastewater treatment plant employees?
	$\sqrt{\text{Check one box.}}$ Yes \square No
	Explain: Budget allocated and training schedule set at beginning of each year
•	What percentage of the continuing education expenses of the operator-in-charge were paid for:
	By the permittee? 100 By the operator? 0%
•	Add together the E and G point values and place the sum in the box below at the right.
	TOTAL POINT VALUE FOR PART 7: $0 mtext{ (max = 100)}$

Permit #: LA0063991

PART 8: FINANCIAL STATUS

Α.	Are User-Charge Revenues sufficient to cover operation and maintenance expenses?				
	$\sqrt{\text{Check one box.}}$	Yes No	If No, How are O&M costs financed?		
B.	What financial resources do you land reconstruction needs?	have available to p	pay for your wastewater improvements		
	Revenue generated f services.	from the sale of wa	ater and sewer		

Permit #: LA0063991

PART 9: SUBJECTIVE EVALUATION

A.	Collection System Maintenance			
i.	Describe what sewer system maintenance work has been done in the last year.			
	General maintenance (smoking & camera). Less that of collection system has needed repair.	n 1%		
ii.	Describe what lift station work has been done in the last year.			
	General maintenancepumps replaced as needed. Typically burnt up due to clogging.			
iii.	What collection system improvements does the community have under construction for the next 5 years?			
	Lift stations will be renovated as necessary. Electric panels will be upgraded accordingly.	al		
В.	If you have ponds please answer the following questions: N/A	√ Check or	ne box.	
i. ii.	Do you have duckweed buildup in the ponds? Do you mow the dikes regularly (at least monthly), to the waters edge?	Yes Yes	☐ No ☐ No	
iii.	Do you have bushes or trees growing on the dikes or in the ponds?	Yes	☐ No	
iv. v. vi. vii.	Do you have excess sludge buildup (> 1foot) on the bottom of any of your ponds? Do you exercise all of your valves? Are your control manholes in good structural shape? Do you maintain at least 3 feet of freeboard in all of your	Yes Yes Yes	No No No	
	ponds? Do you visit your pond system at least weekly?	Yes Yes	No No	

	Permit #: LA0063991
C.	Treatment Plants
i.	Have the influent and effluent flow meters been calibrated in the last year?
	X Yes
	$\frac{\text{N/A}}{\text{Influent flow meter calibration date(s)}} \frac{\text{May 2014}}{\text{\textit{Effluent flow meter calibration date(s)}}}$
ii.	What problems, if any, have been experienced over the last year that have threatened treatment?
	NONE
iii.	Is your community presently involved in formal planning for treatment facility upgrade?
	\vee Check one box. \square Yes \square No If Yes, Please describe:

	Permit #: LA0063991				
D.	Preventive Maintenance				
i.	Does your plant have a written plan for preventive maintenance on major equipment items?				
	$\sqrt{\text{Check one box.}}$ Yes \square No If Yes, Please describe:				
	As per manufacturer directives in O&M manual.				
ii.	Does this preventive maintenance program depict frequency of intervals, types of lubrication and other preventive maintenance tasks necessary for each piece of equipment?				
•••	X Yes No				
iii.	Are these preventive maintenance tasks, as well as equipment problems, being recorded and filed so future maintenance problems can be assured properly?				
	X Yes No				
E.	Sewer Use Ordinance				
i.	Does your community have a sewer use ordinance that limits or prohibits the discharge of excessive conventional pollutants (BOD, TSS or pH) or toxic substances to the sewer system from industries, commercial users and residences?				
	\vee Check one box. \square Yes \square No If Yes, Please describe:				
	There is no pretreatment program in effect. There are no categorical industrial users and no adverse effects from current users.				
ii.	Has it been necessary to enforce?				
	√ Check one box.				
	N/A				
iii.	Any additional comments about your treatment plant or collection system? (Attach additional sheets if necessary.)				

POINT CALCULATION TABLE

	Actual Values	Maximum
Part 1: Influent Flow/Loadings	0	80 points
Part 2: Effluent Quality / Plant Performance	0	100 points
Part 3: Age of WWTF	34	50 points
Part 4: Overflows and Bypasses	0	100 points
Part 5: Ultimate Disposition of Sludge	40	100 points
Part 6: New Development	0	30 points
Part 7: Operator Certification Training	0	100 points

TOTAL POINTS:

74 = Acceptable

ATTACHMENT - RESOLUTION

ST. TAMMANY PARISH MWPP RESOLUTION

Resolved the Municipal Water Pollution Prevention Environmental Audit Report which

Resolved that the village/town/city of <u>Westwood</u> sewered area informs the Louisiana Department of Environmental Quality that the following actions were taken by <u>St. Tammany Parish Council.</u>

1.

CLERK

WESTWOOD REGIONAL WUTD ASITE LAYOUT AI#19917, LACOL3991

