

ST. TAMMANY PARISH COUNCIL

ORDINANCE

ORDINANCE CALENDAR NO. 3266 ORDINANCE COUNCIL SERIES NO. 06-  
COUNCIL SPONSOR MR. BILLIOT PROVIDED BY ENVIRONMENTAL SERVICES  
INTRODUCED BY MR. BILLIOT SECONDED BY MR. CANULETTE  
ON THE 6TH DAY OF APRIL 2006

ORDINANCE ESTABLISHING WASTEWATER PRE-TREATMENT  
STANDARDS FOR INDUSTRIAL AND LIGHT INDUSTRIAL WASTEWATER  
FACILITIES CONNECTED TO PARISH OWNED TREATMENT FACILITIES;  
AND PROVIDE FOR REPEAL, SEVERABILITY, AND DATE OF ENACTMENT

WHEREAS, the Parish owns and operates treatment facilities that provide wastewater treatment services for a number of industrial and light industrial customers; and,

WHEREAS, the Parish as permittee for Louisiana Pollution Discharge Elimination System (LPDES) permits LA0119589 and LA0048941, administered by the Louisiana Department of Environmental Quality (LDEQ), therefore assumes all liabilities associated with noncompliance with said permits; and,

WHEREAS, said treatment facilities were designed and installed to treat wastewater consistent with the wastewater volume and loading criteria provided by said customers; and,

WHEREAS, LA R.S. 33:4064.4(C) sets forth that the St. Tammany Parish Department of Environmental Services "shall be authorized to adopt rules and regulations relative to the impact upon, and the construction, modification, perpetuation, sustenance, operation, maintenance, connection and inspection of sewerage and water systems and the provision and/or supervision of environmental services, all within the unincorporated portion of St. Tammany Parish..."

THE PARISH OF ST. TAMMANY ORDAINS, that wastewater generated from the industrial and light industrial customers shall not exceed the following standards prior to said wastewater entering the wastewater collection systems owned and operated by St. Tammany Parish:

<u>Parameter</u>	<u>Limit</u>
BOD <sub>5</sub>	248 mg/L
COD	1,133 mg/L
Oil & Grease	128 mg/L
TSS	368 mg/L
pH	not less than 5.8 S.U. and not more than 9.6 S.U.

Failure by any customer to provide this quality wastewater prior to treatment by St. Tammany Parish shall result in termination of wastewater treatment services and/or water service at the sole discretion of St. Tammany Parish.

REPEAL: All Ordinances or parts of Ordinances in conflict herewith are hereby repealed.

SEVERABILITY: If any provision of this Ordinance shall be held to be invalid, such invalidity shall not affect other provisions herein which can be given effect without the invalid provision and to this end the provisions of this Ordinance are hereby declared to be severable.