

"This is only the scope of work for the project. For more information, interested parties should contact Procurement at purchasing@stpgov.org to ensure receipt of a full project package, to be listed as a plan holder and to ensure any addenda to the project package are received."

Scope of work/Services

This is a Capital Improvement Project. The work specified in this project will require the Contractor to supply all labor and materials necessary to remove and replace two (2) concrete road panels. Panels are 12' x 15' x 8" and shall be constructed of 4000 PSI Class B Concrete with an accelerator added (high early) and contain 12" x 6" x O/1 (0.25) welded wire mesh and be doweled into the adjoining panels with $\frac{3}{4}$ " bars 24" on Center. The Contractor shall level and repair base material as required. Base material identified by the Inspector, to be removed, shall be replaced with A-4 Select material. All work shall be done in accordance with LA DOTD Standard Specifications for Roads and Bridges, Sec. 602, 2016 Edition. Work shall include all saw cuts necessary to remove the panels without damaging the adjoining panels. All panels to be removed are marked in orange paint. Removed concrete shall be delivered to the Hwy 59 road barn. All debris is to be removed at no direct pay.

The Contractor shall provide all necessary construction signs, barricades and flagmen per the LA DOTD Standard Specifications for Roads and Bridges, Section 713, 2016 Edition.

All supervision, labor, materials, supplies, equipment, and permits required to complete the work shall be included in the lump sum quote.

Contractor shall have thirty (30) days from Notice to Proceed issued by the Parish to complete the project.

Any work that may be reasonably inferred from the specifications or drawings as being required to produce the intended result shall be supplied whether or not it is specifically called for. Work, materials or equipment described herein which so applied to this project are covered by a well-known technical meaning or specification shall be deemed to be governed by such recognized standards unless specifically excluded.

A Quote Guarantee **is not** required for this project.