

This is just the scope of work. Please email Procurement at purchasing@stpgov.org for more information.

Scope of work/Services

The Contractor shall provide all materials and labor necessary to re-install two (2) residential drives and two (2) headwalls. The Contractor shall also provide and install sod at a 13' x 13' area between drives and at areas disturbed during construction.

Locations are as follows:

104 Manassas Ave. Slidell, La. 70460

108 Manassas Ave. Slidell, La. 70460

Specifications for the drives and headwalls are as follows:

The concrete drives are to be 6" thick with 4000 psi concrete, contain 6" x 6" x 10 gauge welded wire mesh and are to be doweled into the adjoining concrete with 5/8" dowel pins at 24" centers to existing road panels. The drive address and dimensions are 22'2" x 11' at 104 Manassas Ave. and 12'4" x 12' at 108 Manassas Ave.. The Contractor shall remove stone to the required depth and level and patch base material, as required. All work shall be done in accordance with LADOTD Standard Specifications for Roads and Bridges, Section 706. The Contractor shall replace and seal joints in kind, i.e., construction joints or expansion joints. All debris is to be removed at no direct pay.

The head walls are to be constructed out of 4000 PSI Concrete and include 5/8 re-bar. The dimensions for the head walls are 6' wide by 4' tall and 6" thick. The head walls shall extend 6" below bottom of the culvert. The work shall include all excavation, back fill and compaction of soil around headwall. All work shall be performed in accordance with the LADOTD Standard Specifications for Roads and Bridges, 2006 Edition, Section 805. All debris is to be removed at no direct pay.

The Contractor is to verify all dimensions and lengths.

The work shall include all necessary signage, barricades and flagmen per LA DOTD Standard Specifications for Roads and Bridges, 2006 Edition, Section 713 and mobilization of equipment per Section 727.

The Contractor will have thirty (30) days to complete the project from the date stated in the Notice to Proceed issued by the Parish.

A Quote Guarantee **is not** required for this project.