

March 5, 2018

Please find the following addendum to the below mentioned QUOTE.

Addendum No.: 1

Quote#: 314-00-17-100-1

Project Name: Johnny F Smith Blvd

Quote Due Date: Thursday, March 8, 2018

QUESTIONS & ANSWERS:

Question #1: The plans and specs don't call for colored stamped concrete. Is any required,

as there is some existing in this location?

Answer #1: No, colored stamped concrete is not required. Rough finish such as broom,

tine or burlap sack will be required.

End of Addendum #1