

## **January 15, 2021**

Please find the following addendum to the below mentioned BID.

Addendum No.: 1

**Bid#**: 20-36-2

**Project Name**: Robbert Park Drainage Improvements

**Bid Due Date**: February 10, 2021

## **QUESTIONS & ANSWERS:**

Question 1: A. On the **General Notes** (12) On the General Notes- states that in the event of Conflict ,Information Information and Requirements Herein Shall Supersede

 $Supplemental\ Specifications\ ,\ Standard\ Specifications\ and\ Standard\ Plans$ 

B. In **Section 03 Summary of Work -** IV.Other Requirements (as applicable) When not otherwise specified herein, all work and material shall conform to the requirements of the Louisiana Department of Transportation and Development hereafter called LADOTD (2016 Edition of Louisiana Standard Specifications fro Roads and Bridges).

Which one of these paragraphs is correct? They appear to contradict one another.

Answer 1: They are both correct. The Parish deems there is no conflict between these two sections.

Question 2: Can A-2000 (Contech) Pipe be used in lieu of RCP or RCPA under road crossings as a equal?

Answer 2: No plastic pipe will be allowed, contractor to bid as-is.

Question3: There is a effluent sewer pipe- tie in called out on Sheet 04. Who identifies the locations

? The locations are not clearly identified on the plans to insure they are installed to eliminate house connection back up to private properties and creating a

unnecessary liability to the owner or contractor.



Answer 3: Contractor's responsibility.

Question 4: There is not a pay item for sewer tie-ins on the unit price sheets, however in the general

notes it states no direct pay. This creates a unbalanced position on this item. If a each item was applied to this the quantities could be adjusted as per field adjustments per project

managers. Can a pay item be added for this work?

Answer 4: No item will be added, contractor to bid as-is.

<< End of Addendum # >>