



ST. TAMMANY PARISH

PATRICIA P. BRISTER
PARISH PRESIDENT

May 26, 2017

Please find the following addendum to the below mentioned BID.

Addendum No.: 1

Bid#: 300-00-17-40-2

Project Name: Tchefuncte Parc Bridge at Black River

Bid Due Date: Wednesday, May 31, 2017

QUESTIONS & ANSWERS:

Question 1: What is the depths of the Sewers and is it Gravity or Forced?

Answer 1: Gravity, the depths of the existing line are roughly the same as the proposed. These gravity lines go to a Tammany Utilities lift station on the utility lot. The force main coming from the lift station is not anticipated to be in conflict or need to be relocated.

Question 2: We don't see any information or unit pricing for relocating the electrical systems that are visible per our site inspection. Please clarify the process and who pays and how is this work included in the bid. Please Clarify.

Answer 2: All other utilities will be moved by their respective owners.

Question 3: Does the Parish have a ROE with HOA or does the parish own all the property being accessed for this project? Please Clarify.

Answer 3: No right of entry is required for use of the utility lot.

Question 4: Is materials testing required? If so who pays for this contractor or parish? Please Clarify

Answer 4: Material testing is required at the contractor's expense.



ST. TAMMANY PARISH

PATRICIA P. BRISTER
PARISH PRESIDENT

Question 5: Due to the weight (7,000 lb per ft) of the material being used for this project, are pilings needed to support these structures?

Answer 5: No pilings are required. However, additional bedding material may be required if unanticipated soft conditions are encountered. This is unlikely given that 3 ft of bedding material is specified in the plans.

<< End of Addendum #1 >>