



## ST. TAMMANY PARISH

MICHAEL B. COOPER  
PARISH PRESIDENT

**June 11, 2021**

Please find the following addendum to the below mentioned BID.

**Addendum No.:** 1

**Bid#:** 21-15-2

**Project Name:** 2021 District 12, 13, 14 Rd Improvements

**Bid Due Date:** Wednesday, June 16, 2021

### QUESTIONS & ANSWERS:

---

**Question 1:** On Brushfire Ln. the asphalt is overlay onto the gutter will we be replacing the asphalt onto the gutter or will we be tying back into the toe of the gutter? Also, on Brushfire lane, in the cul de sac, will the concrete drive that is extended into the cul de sac needs to be removed and patched or just overlay?

**Answer 1:** The Contractor will be required to tie in to the face of the gutter line which will require extra milling on the edge of the street to get down below the top of the gutter line. The Contractor will be required to remove the existing asphalt from the gutter line and dispose of it. As far as the concrete driveway in the cul-de-sac we feel that it is just a skim coat or wash out and will come up easily while milling.

**End of Addendum # 1**