



## ST. TAMMANY PARISH

MICHAEL B. COOPER  
PARISH PRESIDENT

**November 24, 2020**

Please find the following addendum to the below mentioned QUOTE.

**Addendum No.:** 2

**Quote#:** 20-36-1

**Project Name:** Safe Haven Extend HVAC Controls

**Quote Due Date:** Tuesday, December 1, 2020

### **GENERAL INFORMATION:**

---

1. Section 2.1- Scope of Work/Services- DELETE in its entirety and replace with the REVISED- Section 2.1 Scope of Work/Services (attached).

### **ATTACHMENT:**

---

1. **REVISED – Section2.1 Scope of Work/Services.pdf**

**End of Addendum #2**

In the event that Contractor is a member of a corporation, partnership, L.L.C., L.L.P., or any other juridical entity, as an additional provision, Contractor should supply a certified copy of a corporate resolution or other written evidence of authority of person signing the quote/proposal.

**QUOTES SHALL BE OPENED PUBLICLY AT THE PHYSICAL LOCATION IDENTIFIED ABOVE AND ONLY RESPONDENTS SUBMITTING QUOTES SHALL BE IDENTIFIED ALOUD.**

## **PART II: SCOPE OF WORK/SERVICES**

### **2.1 Scope of work/Services**

St. Tammany Parish government seeks a contractor to provide, install and commission (9) ASI ASIC/3 Controllers to Safe Haven Quad "B" (23363 South Robin Road, Mandeville, LA 70448) and integrate them into existing ASI Workstation located in the Mechanical Plant (23592 Sparrow Road, Mandeville, LA 70448).

The project consists of the following;

- Provide and Install (9) Brand new and unused ASI **ASIC/3 9520** Controllers in existing large Honeywell control box.
- Provide and install all sensors, control wiring, and associated electrical to power and operate devices to match operation in Quad A.
  - Discharge air sensor
  - Return air humidity sensor
  - Chilled water actuator
  - Reheat water-actuator
  - Supply fan status indication
  - Outside air damper control
  - Float switch on emergency drain pan
- Provide and install ethernet communications from Quad B to Boiler Room Office to wirelessly integrate the new controls into the existing ASI workstation located in the Site mechanical room.
- Provide graphics, alarms, and trends on front end workstation for new controllers

Any and all items not specifically listed shall be included when deemed required as part the scope in order to complete the work. Contractors shall determine a comprehensive scope of work through review of the Drawings & Specifications and review of site conditions by attending the non-mandatory project site pre-quote conference walkthrough.

The Contractor is to provide all supplies, tools, materials, man lifts, scaffolding, etc. to complete this project under the submitted bid. The jobsite is to be left in a clean, safe and reasonable manner at the end of each workday. Upon completion of the project, the Contractor will remove any leftover materials, construction debris, trash, etc. from the jobsite.

COVID 19 Safety protocols are to be adhered to including; but not limited to: Daily temperature checks, daily log in sheets, daily questionnaires, etc.



## ST. TAMMANY PARISH

MICHAEL B. COOPER  
PARISH PRESIDENT

**November 16, 2020**

Please find the following addendum to the below mentioned QUOTE.

**Addendum No.:** 1

**Quote#:** 20-36-1

**Project Name:** Safe Haven Extend HVAC Controls

**Quote Due Date:** Tuesday, December 1, 2020

### **GENERAL INFORMATION:**

---

1. A Non-Mandatory quote meeting will be held on **Monday, November 23, 2020** at 9:00 am located at 23251 Robin Road Mandeville, LA 70448(Quad A).
2. Section 2.1 Scope of Work/Service – Reference made regarding “mandatory project site pre-bid conference” is changed to “non-mandatory project site pre-quote meeting”.

**End of Addendum #1**