



ST. TAMMANY PARISH

MICHAEL B. COOPER
PARISH PRESIDENT

February 23, 2022

Please find the following addendum to the below mentioned BID.

Addendum No.: 1

Bid#: 22-5-2

Project Name: River Road @ Lee Rd. Intersection Improvements, Airport Rd. (Covington)

Bid Due Date: Tuesday, March 8, 2022

QUESTIONS & ANSWERS:

Question #1 - Can owner please provide Geotechnical Report?

Answer #1 - No, the parish only took pavement cores on the roadway which showed an average depth of 3.5" of asphalt.

Question #2 - Clearing on Lee Road will require a lane closure. Clearing is typically a day time operation. Will special consideration be given to allow for day time lane closures on Lee Rd. during non-peak hours.

Answer #2 - Lane closures are only allowed between 7:00 pm and 5:00 am per the DOTD Permit.

Question #3 - Proposed drainage work in lateral ditches near St. Gert. may require a road closures. Will special consideration be given to allow for road closures with detours on River Road?

Answer #3 - Special Consideration will be given on a case by case basis for road closures. Lane closures will be allowed as long as two-way traffic is maintained.



ST. TAMMANY PARISH

MICHAEL B. COOPER
PARISH PRESIDENT

Question #4 - Can owner please provide ADT on Lee Road?

Answer #4 - No Parish supplied ADT is available, this is a state road.

Question #5 - Plan sheet 7 on River Rd Improvements – there appears to be a conflict in drainage calls out between plan and profile – particularly structure number 416, 418, 419, 420, 423. Which is correct?

Answer #5 - There are two corrections:

- 419 is labeled incorrectly as 416 in the profile view; and
- 423 is labeled incorrectly as 420 in the profile view.

<< End of Addendum #1 >>