



## ST. TAMMANY PARISH

PATRICIA P. BRISTER  
PARISH PRESIDENT

**January 3, 2019**

Please find the following addendum to the below mentioned BID.

**Addendum No.:** 1

**Bid#:** 622-10-18-65-2

**Project Name:** Submersible Wastewater Pumps

**Bid Due Date:** January 8, 2019

### **GENERAL INFORMATION:**

---

1. Bids will be received at 21454 Koop Dr., Suite 2F, Mandeville, LA 70471 from each bidder or his agent and given a written receipt, by certified mail with return receipt requested, or electronically at [www.bidexpress.com](http://www.bidexpress.com).

### **QUESTIONS & ANSWERS:**

---

Question #1: Are sure you want these pumps to have non-witnessed performance test at the factory?? This would add lots of cost to the bid. All the pumps you have now are not performances tested. Please advise

**Answer #1: Factory pump testing is required as specified.**



## ST. TAMMANY PARISH

PATRICIA P. BRISTER  
PARISH PRESIDENT

Question #2: Is there any reason why the Barmesa pumps are not an approved pump this year as they were last year?

**Answer #2: Any manufacturer not listed in the bidding package must submit for prior approval as described in the bidding package. Information submitted with the request for prior approval must be sufficient in scope to demonstrate full conformance to the technical specification.**

Question #3: Purchasing, I would like to file an addendum for Bid # 622-10-18-65-2 – Submersible Wastewater Pumps. I have attached all of the info requested for and addenda. If you have any questions please let me know.

**Answer#3: The information submitted for prior approval for the manufacturer designated as “Barmesa” was insufficient in scope to demonstrate full conformance to the technical specification. The information submitted was sufficient to demonstrate that each of the pump models requested for listing as a prior approved equivalent did not conform to some requirements of the technical specification. Therefore, there are no models of “Barmesa” pumps listed as a prior approved equivalent.**

<< End of Addendum #1 >>