



ST. TAMMANY PARISH

PATRICIA P. BRISTER
PARISH PRESIDENT

June 12, 2018

Please find the following addendum to the below mentioned RFP.

Addendum No.: 1

RFP #:622-10-18-11-3

Project Name: Camera Northlake and Bon Temps Water Wells

RFP Due Date: Wednesday, June 27, 2018

GENERAL INFORMATION:

1. The camera survey of the Northlake Behavioral Health System Tammany Utilities Water Facility (Northlake), Safe Haven Campus, 23515 US-190, Mandeville, LA 70448 (S48-08S-12E) has been removed from this Request for Proposal (RFP).
2. The estimate for the RFP has been reduced from \$30,000 to \$15,000 as a result of the removal of Northlake.
3. The Pre-Proposal Conference has been relocated to the Bon Temps well site in the Bon Temps Village (south east corner-behind Franco's Health Club and Spa), Mandeville, LA 70471 (S54-T08S-R10E). The date and time remain unchanged.
4. Please delete PART II: SCOPE OF WORK/SERVICES, Section 2.1 Scope of Work/Services and replace with PART II: SCOPE OF WORK/SERVICES, Section 2.1 Scope of Work/Services-REVISED (Attached).
5. Please delete PART V: GENERAL PROVISIONS, Section 5.3 Proposal Clarifications Prior to Submittal, Section 5.3.1 Pre-proposal Conference and replace with PART V: GENERAL PROVISIONS, Section 5.3 Proposal Clarifications Prior to Submittal, Section 5.3.1 Pre-proposal Conference-REVISED (Attached).
6. Please delete ATTACHMENT "A" – Pricing Sheet and Project Specifications and replace with ATTACHMENT "A" – REVISED, Pricing Sheet and Project Specifications (Attached).



ST. TAMMANY PARISH

PATRICIA P. BRISTER
PARISH PRESIDENT

ATTACHMENTS:

1. PART II: SCOPE OF WORK/SERVICES, Section 2.1 Scope of Work/Services-REVISED.pdf
2. PART V: GENERAL PROVISIONS, Section 5.3 Proposal Clarifications Prior to Submittal, Section 5.3.1 Pre-proposal Conference-REVISED.pdf
3. ATTACHMENT "A" – REVISED, Pricing Sheet and Project Specifications.pdf

<< End of Addendum # 1 >>

PART II: SCOPE OF WORK/SERVICES

2.1 Scope of Work/Services - REVISED

The Parish requires camera video survey of the community water wells at the following location and as detailed on Attachment "A":

1. Bon Temps Tammany Utilities Water Facility (Bon Temps)
Bon Temps Village (south east corner-behind Franco's Health Club and Spa)
Mandeville, LA 70471 (S54-T08S-R10E)

The Bon Temps water well is a flowing well with a static water level of approximately sixty (60') feet above the ground. The water well is approximately four (4") inches in diameter and approximately two thousand seventy nine (2,079') feet in depth. The water well is currently offline, and disconnected from the system. There is no pump in the water well.

Parish shall review and approve procedures and video equipment to be utilized prior to mobilization. The camera shall be at least a two (2") inch real time camera. The camera survey shall be the full depth calibrated to zero depth at the top of casing. The depth shall be continuously displayed on the completed video survey. The completed video survey shall be submitted to the Parish on a DVD labeled with the Owner's name, name of facility, and date of the survey. A report with observations, conclusions, and recommendations shall accompany the completed video surveys.

A Pre-Proposal Conference shall be held at the Bon Temps well site at 10:00 AM on Thursday, June 14, 2018. Attendance is strongly encouraged.

All work, equipment, materials, supplies, labor, incidentals, tools and labor required to complete the work shall be included in the proposal.

Time period for completion of the work shall be thirty (30) days from Notice to Proceed issued by the Parish.

PART V: GENERAL PROVISIONS

5.3 Proposal Clarifications Prior to Submittal

5.3.1 Pre-proposal Conference - REVISED

A Pre-Proposal Conference will be held at the Bon Temps well site in the Bon Temps Village (south east corner-behind Franco's Health Club and Spa), Mandeville, LA 70471 (S54-T08S-R10E) at 10:00 AM on Thursday, June 14, 2018. Prospective Proposers may participate in the conference to obtain clarification of the requirements of the RFP and to receive answers to relevant questions. Any firm intending to submit a proposal should have at least one duly authorized representative attend the Pre-proposal Conference.

Although impromptu questions will be permitted and spontaneous answers will be provided during the conference, the only official answer or position of the Parish will be stated in writing in response to written questions.

ATTACHMENT "A" - REVISED

Proposal Pricing Sheet

CAMERA NORTHLAKE & BON TEMPS WATER WELLS

RFP # 622-10-18-11-3

Provider agrees to abide by all St. Tammany Parish Government (Parish) General Conditions (furnished upon request), and acknowledges receipt of and has reviewed a copy of the Parish's Insurance Requirements (as attached) and agrees to maintain such insurance coverage(s) throughout the duration of the project, as well as for any subsequent warranty periods. If awarded the project, Provider agrees that no work is to commence under any circumstance until the Provider is provided a notice to proceed by the Parish.

Enter the number the Parish has assigned to each of the addenda that the Provider is acknowledging. The Provider acknowledges receipt of the following:

ADDENDA: _____

Provider: _____

Address: _____

Phone: _____

Email: _____

Location	Cost
Bon Temps Tammany Utilities Water Facility Mandeville, LA 70471 (S54-T08S-R10E)	\$

Total proposal amount (Dollars): _____

Total proposal amount (Written): _____

Provider Signature: _____ Date: _____

Provider Printed Name: _____

Bon Temps Water Well

Bon Temps Tammany Utilities Water Facility
Bon Temps Village (behind Franco's Health Club and Spa)
South East Corner of the Bon Temps Village
Mandeville, LA 70471 (S54-T08S-R10E)

The site is accessible with some access limitations such as: narrow driveway, drainage ditches and trees.

