



ST. TAMMANY PARISH

MICHAEL B. COOPER
PARISH PRESIDENT

March 28th, 2022

Please find the following addendum to the below mentioned BID.

Addendum No.: 2

Bid#: 22-10-2

Project Name: Westwood WWTP Blower

Bid Due Date: April 13th, 2022

GENERAL INFORMATION:

1. Please REMOVE Section 11200-12 of the attachment “Positive Displacement Rotary Lobe Blower Package Specifications” and with the attachment “Specifications – Section 11200-12 – REVISED.” This revised section removes 3.1 – Installation – A and 3.1 – Installation – B from Part 3 – Execution, as installation is not required.

ATTACHMENTS:

1. Specifications – Section 11200-12 – REVISED.pdf

End of Addendum 2

REVISED

POSITIVE DISPLACEMENT ROTARY LOBE BLOWER PACKAGE SPECIFICATIONS

- Blower Enclosure Ventilation Fan Circuit.
 -
 - d. Site Power: 480V 3 Phase 60 Hz. Blower Motor Horsepower: 40 HP 52 FLA 460V/3 Ph/ 60Hz. Ventilation Fan: 0.28 HP 0.62 FLA 460V/ 3 Ph/60 Hz. Control Voltage: 120V 1 Phase 60 Hz.
- G. Nameplates:
1. The blower package shall have at least two weather proof corrosion resistant type nameplates which includes the manufacturer name, model number, year, max pressure difference, equipment number, part number, serial number, voltage, phase, HP, motor rpm, rated temperature, and FLA attached on the outside and inside of the blower package.
- H. Anchor bolts and hardware:
1. Anchor bolts, washers, hex nuts, and all other fastening hardware shall be stainless steel and be supplied by the contractor.
- I. Paint Specification:
1. The blower manufacturer is responsible for surface preparation, priming and finish coating of the blower package and components requiring paint in accordance with the manufacture's standard procedures. Field painting of blower equipment or supplying components that are only prime painted is not acceptable.
 - a. Cast parts are to be painted with a two part gray epoxy primer and two part top coat.
 - b. Fabricated parts are to be painted with a two part gray epoxy primer and two part top coat.
 - c. Sound enclosure parts are to be powder coated.
 - 1) Panels and base paint finish shall be pretreated by de-greasing and phosphate cleaning, then powder coated to a thickness of 70 μm -100 μm on both sides.
 2. The blower package to be painted the blower manufacturer's standard colors.

Part 3 – Execution

3.1 Installation

- C. The blower package shall arrive on site ready for installation. Aligning, adjusting and filling the blower with lubrication shall not be required by the contractor.

3.2 Field Quality Control

- A. Furnish the services of a manufacturer's authorized representative for proper installation to inspect and approve the installation, and to supervise a test run of the blower package.
- B. After the installation and test run has been completed; the blower package shall be given a field test in the presence of the Engineer to verify that operation is satisfactory and in compliance with the Specification. If the blower package does not meet the Specification, corrective measures shall be taken to ensure the machine meets compliance.

3.3 Training

- A. Furnish the services of a manufacturer's authorized representative, who will instruct plant personnel in the operation and maintenance of the blower package. All procedures shall be covered including preventive maintenance, method of controlling the blower package and troubleshooting.



ST. TAMMANY PARISH

MICHAEL B. COOPER
PARISH PRESIDENT

March 25th, 2022

Please find the following addendum to the below mentioned BID.

Addendum No.: 1

Bid#: 22-10-2

Project Name: Westwood WWTP Blower

Bid Due Date: April 13th, 2022

GENERAL INFORMATION:

1. A non-mandatory site visit will be held on Wednesday, March 30th at 10:00 A.M. at the Westwood Treatment Plant facility located at 176 Judge Tanner Boulevard, Covington, LA 70433 (meet at the front gate).

<< End of Addendum 1 >>